



# Biannual Consumer Confidence Report (CCR)



## Jan-Jun 2021 Water Quality Report Marine Corps Installations Pacific Marine Corps Base Camp S.D. Butler, Camp Foster Okinawa, Japan

### Introduction

This is a biannual report on the quality of tap water delivered to Marine Corps Base (MCB) Camp S.D. Butler, Camp Foster. The purpose of this report is to provide you, our customers, with general information about the quality of water you drink.

### What is a Consumer Confidence Report?

In 1996, Congress amended the Safe Drinking Water Act (SDWA) to require all community water systems in the United States to provide their customers with a brief annual water quality report called a Consumer Confidence Report (CCR). In 2020, the CCR was added to the Japan Environmental Governing Standards (JEGS), making it a requirement for the United States Marine Corps (USMC) to prepare an annual water quality report modeled after the SDWA. In February 2021, USMC established the requirement for overseas drinking water systems serving populations over 10,000 to publish CCRs biannually in order to be consistent with CONUS installations.

### Safe Drinking Water

Drinking water regulations require that all installation water supply systems are sampled and analyzed for a variety of contaminants in drinking water. During January to June 2021, your drinking water met health-based water quality standards contained in the JEGS. MCB Camp Butler, G-F, Environmental Affairs Branch (EAB) and 18th Medical Group, Bioenvironmental Engineering Flight (BEF) personnel are committed to providing safe drinking water to you and your family. Our routine monitoring program, which follows water quality standards and monitoring requirements set forth in the JEGS, enables us to maintain optimal water quality on Camp Foster.

### Information about Drinking Water Contaminants

All drinking water, including bottled water, may contain trace amounts of contaminants dissolved in the water. The presence of trace contaminants in the water does not necessarily indicate that the water poses a health risk. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, naturally-occurring radioactive material, and can pick up substances resulting from the presence of animals or human activity. Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive contaminants can be naturally occurring or be the result of oil and gas production, and mining activities. In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for

contaminants in bottled water, which must provide the same protection for public health. In Japan, the Government of Japan (GOJ) and the US Forces, Japan, also regulate the quality of drinking water. Our monitoring program allows us to avoid potential health impacts that may occur if we drink water containing contaminants over long periods of time above the standards set forth in the JEGS.

### Do I need to take Special Precautions?

Our monitoring program identifies contaminants in drinking water and allows us to avoid potential health impacts that might occur if we consume water containing contaminants over long periods of time above the standards set forth in the JEGS. However, some people may be more vulnerable to contaminants than the general population. For example, immuno-compromised individuals such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, the elderly, and infants can be particularly at risk from contaminants. These individuals should seek medical advice about drinking water from their health care providers if they have questions.

### Camp Foster Water System Information

The Camp Foster drinking water system is jointly operated and maintained by the G-F Facilities Maintenance Branch (FMB) and the 18th Civil Engineer Squadron (CES). The water is distributed from the Chatan water treatment plant to Camp Foster. The water supply to this treatment plant is a combination of surface waters (reservoirs and rivers), groundwater wells, and a desalination plant fed by the East China Sea.

### Monitoring of Your Drinking Water

The G-F EAB is responsible for drinking water monitoring of Marine Corps-owned infrastructure including all non-housing areas on Camp Foster. The BEF is responsible for drinking water monitoring of Air Force-managed military family housing on Camp Foster. Together, the G-F EAB and the BEF are committed to providing safe drinking water to you. We use only EPA and GOJ approved laboratory methods to analyze your drinking water. Trained personnel collect water samples from the distribution system and residential taps. Samples are then shipped to an accredited laboratory where water quality analyses are performed. The BEF and contracted personnel collected all required routine monitoring samples during January to June 2021 none of which were at a level higher than the JEGS Maximum Contaminant Level (MCL). Results from these sampling are located on the next page.



For More Information Contact:

MCB Camp Butler  
Environmental Affairs Branch  
Water Program  
Patricia Dodson  
DSN: 315-645-5197  
patricia.dodson@usmc.mil

## Jan-Jun 2021 Water Quality Table Camp Foster

Inorganic Contaminants <sup>1</sup>	Violation? Yes/No	Units	Highest Level Detected	MCL	AL	Likely Source of Contamination
Nitrate	No	mg/L	0.6	10		Runoff from fertilizer use; leaching septic tanks/sewage; erosion of natural deposits
Total Nitrate/Nitrite	No	mg/L	0.6	10		
Microbial Contaminants	Violation? Yes/No	Units	Highest Level Detected	MCL <sup>2</sup>	AL	Likely Source of Contamination
Total Coliform Bacteria	No	N/A	N/A	>1 positive sample per month, or any repeat sample is positive	N/A	Naturally present in the environment
Synthetic Organic Chemicals/Volatile Organic Compounds <sup>1</sup>	Violation? Yes/No	Units	Highest Level Detected	MCL	AL	Likely Source of Contamination
Not required during Jan-June 2021						
Radionuclides <sup>3</sup>	Violation? Yes/No	Units	Highest Level Detected	MCL	AL	Likely Source of Contamination
Gross Alpha	No	pCi/L	1.14±1.03	15	N/A	Erosion of natural deposits
Radium-226 and Radium-228 (combined)	No	pCi/L	0.798±0.936	5		
Residual Disinfectants	Violation? Yes/No	Units	Highest Running Annual Average <sup>4</sup>	MRDL <sup>4</sup>	AL	Likely Source of Contamination
Free Chlorine	No	mg/L	0.40	4.0	N/A	Water additive use to control microbes
Disinfectant/Disinfection Byproducts <sup>5</sup>	Violation? Yes/No	Units	Highest Running Annual Average <sup>6</sup>	MCL <sup>6</sup>	AL	Likely Source of Contamination
Total Trihalomethanes	No	mg/L	0.045	0.08	N/A	By-products of drinking water chlorination
Haloacetic Acids	No	mg/L	0.007	0.06		
Lead and Copper <sup>1</sup>	Violation? Yes/No	Units	90 <sup>th</sup> Percentile Value	Sites Exceeding AL / No. of Sites	AL <sup>7</sup>	Likely Source of Contamination
Not required during Jan-June 2021						
PFAS <sup>8</sup>	Violation? Yes/No	Units	Highest Level Detected	HA	AL	Likely Source of Contamination
Not required during Jan-June 2021						
<b>Abbreviations Used:</b> AL: action level CY: calendar year MCL: maximum contaminant level MRDL: maximum residual disinfectant level mg/L: milligrams per liter ng/L: nanograms per liter pCi/L: picocuries per liter µg/L: micrograms per liter N/A: not applicable PFAS: Per- and polyfluoroalkyl substances PFOS: Perfluorooctanesulfonic acid PFOA: Perfluorooctanoic acid						
<b>Definitions Used:</b> MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MRDL: Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. HA: Health Advisories provide information on contaminants that can cause human health effects and are known or anticipated to occur in drinking water. The EPA establishes HA levels to provide technical information based on the best available data to public water systems. These levels are non-enforceable and non-regulatory.						
<b>Notes:</b> 1. Only the parameters required for monthly, quarterly samples were included in the biannual reporting. Annual sampling will be reported in the annual CCR. 2. This is the total coliform-related operational evaluation level (OEL). The MCL for E-Coli is exceeded when routine and repeat samples for total coliform are positive or when a system fails to take repeat samples following positive samples. 3. Uranium was monitored in CY21, and results were non-detectable. 4. The MRDL for Free Chlorine is based on a running annual average of monthly samples. 5. Bromate was monitored in CY21, and results were non-detectable. 6. The MCLs for Total Trihalomethanes and Haloacetic Acids are based on a locational running annual average of quarterly samples. 7. The AL for Lead and Copper is based on a 90 <sup>th</sup> percentile value – i.e., no more than 10% of all sampled taps. 8. Resampling for PFAS parameters will be conducted in accordance with the most current DoD policy.						

# Frequently Asked Questions

## Why does the water sometimes look rusty?

Rusty or reddish tinted water may occur because of a sudden change in pressure due to fire hydrant flushing, water main breaks, or other disturbances that result in a change to normal water flow. Iron causes the discoloration and is not a health risk. The normal flow of water will usually clear the mains within two hours or less. Check your water by flushing a commode bowl three times every 15 to 20 minutes. If you live on or near the end of a long distribution line, additional flushing may be required. Galvanized iron pipes or fittings within a home or building may also cause discolored water. Running the water will clear the piping system. If the hot water is rusty, the water heater may need to be flushed.

## What is a Boil Water Notice?

Any time a drop in pressure occurs from a water main break or system maintenance, the G-F EAB and/or the BEF will issue a Boil Water Notice and immediate sampling requirements go into effect. Boil Water Notices in these cases are precautionary and do NOT necessarily mean that contamination has been detected or is suspected. In other cases, if total coliform bacteria are detected as part of our routine sampling program, a Boil Water Notice will also go into effect as a precaution while corrective measures are taken. In this case, resampling continues until the corrective measures are completed.

## Is it okay to drink from a garden hose?

The water that supplies the water hose is safe but a garden hose is treated with special chemicals and can contain bacteria and other substances.

## Will using a home water filter make the water safer or healthier?

Most filters improve the taste, smell and appearance of water, but they do not necessarily make the water safer or healthier. If you use filters, please keep in mind that they require regular maintenance and replacement or the filter itself can impact water quality.

## What can I do to improve the quality of my drinking water?

Running the cold water tap for 30 seconds prior to use helps to flush out small amounts of metals that may leach into water that has been sitting in metal pipes overnight. Water used for consumption should always come from the cold water tap. Hot water has more potential to leach metals into the water.

## How will I know if my water is not safe to drink?

Your water supplier must notify you if your water does not meet standards or if there is a waterborne disease emergency. The notice will describe any precautions you need to take, such as boiling your water.

## I don't like the taste/smell/appearance of my tap water? What's wrong with it?

Even when water meets standards, you may still object to its taste, smell, or appearance. Taste, smell and appearance are also known as aesthetic characteristics and do not pose adverse health effects. Common complaints about water aesthetics include: temporary cloudiness (typically caused by air bubbles) or chlorine taste (which can be improved by letting the water stand exposed to the air).

## Does the water system have a lead problem?

The Japan Environmental Governing Standards (JEGS) states 90% of samples must be below the action level. The water system met that criterion in 2020. The water system will continue to be sampled for lead, and the next samples will be taken between July and August 2021. Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking.

## What is PFAS?

Per- and polyfluoroalkyl substance (PFAS) are a group of man-made chemicals that includes PFOS and PFOA. PFAS have been manufactured and used in a variety of industries around the globe, including in the United States since the 1940s. PFAS are found in everyday consumer items, from nonstick cookware to water-resistant clothing. They are also found in certain firefighting foam (AFFF). PFOS and PFOA have been the most extensively produced and studied of the PFAS chemicals.

In May 2016, the EPA issued SDWA lifetime Health Advisories (HA) recommending the individual or combined levels of PFOS and PFOA in drinking water be at or below 70 parts per trillion. This HA offers a margin of protection from adverse health effects over a lifetime of exposure to PFOS and PFOA in drinking water. Currently there is only guidance and not a required or enforceable standard.

Additional information about PFAS can be found at <https://www.epa.gov/pfas>.

## Is a Japanese translation of the CCR available?

All sections of the CCR are written in English. Please contact the G-F EAB at 645-5197/3328 for Japanese translation.

CCRの全てが英文の文書です。日本語訳希望者は施設技術部環境保全課までご連絡下さい。基地内：645-5197/3328 基地外から：098-970-5197/3328.

## Where can I go for additional information?

This CCR will be posted on the MCIPAC web page at <https://www.mcipac.marines.mil/>. Select UNITS tab, then News Center tab, and choose "Consumer Confidence Reports."

It will also be posted on the Kadena AB homepage at <https://www.kadena.af.mil>. Select "About Us" tab, and choose Consumer Confidence Reports.



### G-F Environmental Affairs Branch Water Program

DSN: 645-5197/3328  
Comm: 098-970-5197/3328  
基地内：645-5197/3328  
基地外から：098-970-5197/3328



### 18 AMDS/SGPB Bioenvironmental Engineering Flight

DSN: 634-4752  
Comm: 098-938-1111 ext. 634-4752  
基地内：634-4752  
基地外から：098-938-1111 ext. 634-4752